




MODEL FD-A-S

STATIC CURTAIN INTEGRAL SLEEVE FIRE DAMPERS

HORIZONTAL AND VERTICAL — 1½ HOUR



LISTED AND LABELLED BY:





DESIGNED AND TESTED IN ACCORDANCE WITH UL-555 AND ULC-S112. MEETS ALL NFPA-90A REQUIREMENTS FOR FIRE DAMPERS.

Standard Construction:

- Frame:** 12" Roll Formed Galvanized Steel.
- Blades:** Roll Formed Galvanized Steel, Curtain-Type
- Springs:** Stainless Steel.
- Fusible Link:** U.L. Listed 165°F.
- Vertical Min. Size:** 6"w X 6"h (152 mm x 152 mm)
- Max. Size:** 48"w X 48"h (1219 mm x 1219 mm)
- Horizontal Min. Size:** 6"w X 6"h (152 mm x 152 mm)
- Max. Size:** 40"w X 40"h (1016 mm x 1016 mm)

FD-HA-S12



FD-(V/H) AR-S

- * D = Duct Size Minus 1/4"
- * Maximum Diameter = 46" (1168 mm)

Optional Construction:

- ☐ 14" - 16" Sleeve/Frame
- ☐ Fully Sealed Sleeves
- ☐ Fuse Link 212°F
- ☐ Round Transition (Low Pressure) FD-(V/H) AR-S
- ☐ 3/4" Flange (Sidewall Termination)

Notes: Dampers are furnished approximately 1/4" (6.4mm) smaller than given duct dimensions.

"These Dampers are UL/ULC Approved For Use in Static Systems Where The Fan Shuts Down in the Event of a Fire."

Manufacturer's Recommendations

All moving parts of the damper must be inspected and cycled at intervals not greater than every six months and in accordance with the latest edition of NFPA 90A, 92A, local codes and the actuator manufacturer. In addition, fuse links shall be removed and inspected for corrosion. Dry lubricants are recommended.

Specifications are correct at time of printing. However, as part of our 'continuous improvement program,' we reserve the right to make further improvements without notice. © 2003 NCA Manufacturing

FD-A-S - 02-05

Project:

Contractor:

Location:

Address:

Architect:

P.O. Number:

Engineer:

Date: