Thermal Blanket

Frame: Roll Formed Galvanized

Steel with Safety Edge.

Blades: Roll Formed Galvanized

Steel, Curtain-Type

Sleeve: 20 Ga. Galvanized

wrapped in thermal

blanket.

**Heat Responsive Devices:** 

Fusible Links, 165°F Std.,

212°F available.

Mounting: Vertical.

> Finish: Mill galvanized

> > Standard.

Sizes:

6"w X 6"h Minimum size:

(152 mm x 152mm)

Maximum size: 42"w X 48"h

(1067 mm x 1219mm)

(Typical 3 Sides)\* 311/16 (94 mm) — 3/4" Flange (19mm) Rolled Safety Edge Galv. Steel Interlocking Blades Fusible Link (Replaceable) Opening = Nominal 165°F Standard Galv. Steel Frame - 20/22 Ga. Galvinized Sleeve 12" (305 mm) Standard

1-1/2 HOUR RATING \*For use in fire barriers rated for less than 3 hours.

DESIGNED AND TESTED IN ACCORDANCE WITH UL-555 AND ULC-S112. MEETS ALL NFPA-90A REQUIREMENTS FOR FIRE DAMPERS.

LISTED AND LABELLED BY:

Insulation 3/4" Flange (19 mm) Std.

Notes:


Dampers are furnished approximately actual size of given duct dimensions, (not including thermal blanket). Wall opening must be oversized by 3/8" (9.5 mm) to accomodate thermal

blanket thickness.

Features:

- The FD-OW fire damper has been designed and tested to exceed all UL, ULC, and NFP requirements.
- They are intended for use in static design systems where the grille and damper assembly do not allow for the damper to be mounted in the plane of the fire barrier.
- The damper assembly can be installed from one side of the wall and does not require retaining angles.
- UL 555 and ULC S112 listed and labeled as a 1-1/2 hour vertical/horizontal fire damper.
- The Fire damper, insulation, and sleeve must be ordered from the factory as an assembly.
- \*\*Typical 3 sides for vertical mount (shown) and typical 4 sides when mounted horizontal.

**Grille Mount** With "-OW" Damper



## Options:

12" Std.

(305 mm)

- Longer sleeve lengths.
- **Heavier Sleeve** Gauges.
- Transitions on

(Non Grille) end.

Std. (102 mm)

## Manufacturer's Recommendations

All moving parts of the damper must be inspected and cycled at intervals not greater than every six months and in accordance with the latest edition of NFPA 90A, 92A, local codes and the actuator manufacturer. In addition, fuse links shall be removed and inspected for corrosion. Dry lubricants are recommended.

Specifications are correct at time of printing. However, as part of our 'continuous improvement program,' we reserve the right to make further improvements without notice. © 2004 NCA Manufacturing

Contractor:	Project:
Address:	Location:

Architect: P.O. Number:

Engineer: Date:

NCA Manufacturing, Inc. ■ 1036 South Jupiter Road ■ Garland, Texas 75042 ■ TEL. 972-276-5002 FAX 972-276-6747

- 02-05