





**MODEL FSD-3V-OW-211**  
**COMBINATION FIRE / SMOKE DAMPER**  
**U.L. 555 CLASSIFIED 1 1/2 HOURS / U.L. 555S CLASSIFIED CLASS I**  
**OUTSIDE WALL/PARTITION APPLICATION**

**Standard Construction:**

- Frame:** Roll-formed galvanized steel hat-section with staked corners with integral bracing.
- Blades:** 16 ga. Roll-formed galvanized steel.  
Minimum width: 4.250" (108 mm)  
Maximum width: 7.250" (184 mm)
- Bearings:** Bronze Oilite, press-fit into frame.
- Axles:** Square, plated steel.
- Seals:** Pressure sensitive. Air pressure assists sealing effects.
- Linkage:** Concealed in frame. Linkage bars are .125" (3.2 mm) thick plated steel.
- Sleeve:** Galvanized, wrapped in thermal blanket.

**Heat Responsive Devices:**

- Fusible Links, 165° F and 212° F  
**Snap Disc**, 250° F and 350° F
- Finish:** Mill galvanized.
- Spring:** Stainless steel.
- Sizes:** Minimum Size: 12"w x 10"h (305 mm x 254 mm)  
Single Sect. Max: 36"w x 48"h (914 mm x 1219 mm)  
Max. Size: 42"w x 48"h (1067 mm x 1219 mm)
- Notes:** Dampers are furnished approximately 1/4" (6.4 mm) smaller than given duct dimensions, (not including thermal blanket).  
Wall opening must be oversized by 3/8" (9.5 mm) to accommodate thermal blanket thickness.
- Not recommended with blades running vertically.



**Metal Stud Installation**

PATENTED: U.S. 4,487,214  
CDN. 1,165,661  
U.K. 2,098,475

**Suggested Specification**

Combination Fire/Smoke Dampers shall be Model: FSD-3V-OW-211 by NCA Manufacturing. Fire/Smoke Dampers shall bear the Underwriters' Laboratories labels for both Fire Dampers and Smoke Dampers. Each damper shall be UL/ULC qualified for mounting outside of the plane of the wall to allow 'through the grille' access to actuator and controls. U.L. 555S / U.L.C. S112.1 rating shall be Class I with leakage not to exceed 8 cfm per sq. ft.. at 4.0 inches static pressure for any size. Linkage shall be of the concealed type for maximum free area.

**Manufacturer's Recommendations**

All moving parts of the damper must be inspected and cycled at intervals not greater than every six months and in accordance with the latest edition of NFPA 90A, 92A, local codes and the actuator manufacturer. In addition, fuse links shall be removed and inspected for corrosion. Dry lubricants are recommended.

Specifications are correct at time of printing. However, as part of our 'continuous improvement program,' we reserve the right to make further improvements without notice.

© 2003 NCA Manufacturing

**LISTED AND LABELLED BY:**



**FEATURES**

- The FSD-3V-OW-211 Combination Fire/Smoke Dampers have been designed and tested to exceed all U.L., U.L.C. and N.F.P.A. requirements for fire dampers as well as smoke dampers. They are intended for use where building codes call for the fire damper to also operate as a smoke damper.
  - U.L. 555 and U.L.C. S112 listed and labelled as a 1-1/2 hour fire damper.
  - U.L. and U.L.C. listed for vertical & horizontal mounting.
  - U.L. 555S and U.L.C. S112.1 listed and labelled as a Leakage Class I rated Smoke Damper with airflow in both directions. Class I provides for a maximum leakage of 8 cfm per sq. ft. at 4.0 inches static pressure. As we are constantly expanding our U.L./U.L.C. listings, we suggest you contact the factory for current information.
  - Fusible link/actuator (DLT-1) provides an automatic override system to close and latch damper in the fire mode. **Also available with automatic resettable/override release options: Model STO/R (single thermostat) or Model DTO/R (double thermostat) to provide the fire fighter with complete discretionary control of smoke functions during a fire/smoke emergency. (See STO/R and DTO/R submittal drawings for complete details).** Spring return type damper motor controlled by a smoke detector is recommended to provide proper operation in the smoke mode.
  - Also available are options EFL (Electric Fusible Link) and PFV (Pneumatic Fusible Valve). These options provide quick and economical ways to check damper operations and also provide a Systematic Closure Control. Option PFV allows damper operation without the need/cost for an E-P valve and electrical connection at the damper.
- NOTE: Typical 4 sides when horizontal mounted.

FSD-3V-OW-211 - 02-05

Project:

Contractor:

Location:

Address:

Architect:

P.O. Number:

Engineer:

Date:




**MODEL FSD-3V-OW-211**  
**COMBINATION FIRE / SMOKE DAMPER**  
**U.L. 555 CLASSIFIED 1<sup>1</sup>/<sub>2</sub> HOURS / U.L. 555S CLASSIFIED CLASS I**  
**OUTSIDE WALL/PARTITION APPLICATION**

**PERFORMANCE DATA**


© 2002 NCA Manufacturing

Pressure drop testing was done by an independent laboratory to AMCA Standard 500-D, Fig. 5.3 ductwork upstream & downstream.


**DAMPER SIZE 36 x 36**



**DAMPER SIZE 24 x 24**



**DAMPER SIZE 12 X 12**



FSD-3V-OW-211 - 02-05