

MODEL PBD-100 PARALLEL BLADE DAMPER

Standard Construction:

PBD-100 - 03-05

Standard Constructio	on:
Frame:	3-1/2" X 5/8" (88.9 mm x 15.9 mm) x 16 gauge rollformed
	galvanized steel hat section with welded corners.
Blades:	16 ga, rollformed galvanized steel on 6" (152,4 mm) centers.
Bearings:	Permanently lubricated oilite bronze.
	press fit into frame
Ayles.	1/2" (12.7 mm) dia plated steel
Linkago:	Commercial grade brees pixets machine
Lilikage.	continencial grade, brass pivots, machine
Links an Tis Dark	Iveled to blade.
Linkage Tie Rod:	
Operator Shaft:	6" x 1/2" (152.4 mm x 12.7 mm) dia. plated steel.
Finish:	Mill galvanized.
Minimum Damper Size:	Single Blade: 6"w x 6"h (152.4 mm x 152.4 mm)
	Multi Blade: 6" x 12"h (152.4 mm x 304.8 mm)
Maximum Damper Size:	Single Section: 48"w x 72"h (1,219 mm x 1,828 mm)
	Multi Section: unlimited
Outline	
Options:	
Seeler	Viewl er steinlage steel blade seele (152,4 mm)
Seals.	Viriji of statiliess steel blade seals
0	Plexible stamless site planb sears
Operators:	Motor mounting - factory furnished or by others
	Manual quadrant or chain operator
Finish:	Painted finishes
Face & Bypass:	Right angle and straight line mixing dampers
Notes:	
	• All dampars are fabricated 1/4" (6.4 mm) under listed sizes uplace
	All dampers are fabricated 1/4 (0.4 mm) under listed sizes unless
	specified "actual or exact".
	Dampers must be installed square and free from racking.
	Dampers with multiple sections in both width and height require structural
	supports (by others). NCA recommends that large openings be divided
	with structural members such that dampers will span either the width
	or height of each opening between the structural members with a single
	section.
	All dampers must be installed with blades running horizontally.
	Connect all damper motors to linkage side of operator blade or to (279.4 mm) (279.4
	operator shaft.
	Consult factory if application involves static pressures
	in excess of 2.5 inches w.g.
	< ⊾∖ ≪ ™∖
	MULLION JAMB

Specifications are correct at time of printing. However, as part of our 'continuous improvement program,' we reserve the right to make further improvements without notice. © 1999 NCA Manufacturing

Project:	Contractor:	
Location:	Address:	
Architect:	P.O. Number:	
Engineer:	Date:	



© 1999 NCA Manufacturing Pressure drop testing was conducted by an independent laboratory in accordance with the AMCA Standard 500-D, Fig. 5.3 ductwork upstream & downstream

