



**DIRECT BURIAL
GOLF COURSE SPRINKLER WIRE
INSULATION: POLYETHYLENE
SIZES: 14 AWG - 10 AWG SOLID**



1.0 SCOPE:

1.1 This specification covers single conductor insulated wire sizes 14 AWG, through 10 AWG, utilizing low density high molecular weight polyethylene insulation, suitable for direct burial applications for operating temperatures up to 60°C. Listed by UL or ETL or CSA.

Dual rated wire, listed for use in the USA and Canada, shall be tested physically and electrically in accordance with UL Standards 493 & 83, and CSA Rule C22.2 No. 35. These wires will carry a 30V rating. Paige part numbers will be 150XXX.

2.0 CONSTRUCTION:

2.1 Conductor:

Soft drawn bare copper meeting the requirements of ASTM specification B-3 or B-8.

The construction of the above described wires are identical.

2.2 Temperature Rating:

-55°C +60°C.

2.3 Insulation Thickness:

.045"

2.4 Sunlight Resistance:

Available as an option

2.5 Manufacturer's Identification:

Surface marked with Paige-Electric, voltage rating, size and type, Listing file number, RoHS.

2.6 Listing for Golf Course Sprinkler Wire:

All wire listed for use in the USA shall be tested physically and electrically in accordance with UL Standards 493 and 83. These wires will carry a 600V rating. Paige part numbers will be 150XXX.

3.0 SPLICING RECOMMENDATIONS:

Wire splices are the weak link of any electrical circuit. It is especially important to make proper joints in irrigation systems because the joints are exposed to wet and damp environments that can cause corrosion of the copper conductor and premature failure. Here are Paige Electric's recommendations:

- For direct burial, above ground, or in valve box installations: Model DBR/Y-6 as manufactured by the 3M Company (Paige specification P7364D)
- For installation above ground or in valve boxes: Models 316IR or MGC as manufactured by the 3M Company (Paige specification P7365D), or Silicone-filled wire nuts as manufactured by IDEAL Industries (Paige specification P7372D)