

Reduced Pressure Principle Assembly

with 90°

SPECIFICATION SUBMITTAL SHEE





Size 3/4"-1"

Size 1 1/4"-2"

#### FEATURES

Sizes: 34" 1" 11/4" 11/2" 2"

Maximum working water pressure	175 PSI
Maximum working water temperature	180°F
Hydrostatic test pressure	350 PSI
End connections Threaded	ANSI B1.20.1

## OPTIONS

(Suffixes can be combined)

-with full port QT ball valves (3/4"-1"standard)
U-with full port QT union ball valveS (1 1/4"-2"
standard)
-with stainless steel ball valve handles

# ACCESSORIES

- Air gap (Model AG)
- Repair kit (rubber only)
- Thermal expansion tank (Model WXTP)
- □ Soft seated check valve (Model 40)
- □ Shock arrester (Model 1250)
- QT-SET Quick Test Fitting Set
- Test Cock Lock (Model TCL24)

# Relief Valve discharge port:

3/4" - 1"	-	0.63 sq. in.
1 1/4" - 2"	-	1.19 sq. in.

# DIMENSIONS & WEIGHTS (do not include pkg.)

# APPLICATION

Designed for installation on potable water lines to protect against both backsiphonage and backpressure of contaminated water into the potable water supply. Elbows allow for a very small installation footprint for confined spaces or landscaping. Assembly shall provide protection where a potential health hazard exists.


## STANDARDS COMPLIANCE


- ASSE® Listed 1013
- IAPMO® Listed
- CSA® Certified
- AWWA Compliant C511
- Approved by the Foundation for Cross Connection Control and Hydraulic Research at the University of Southern California

### MATERIALS

Main valve body Access covers Elbows Fasteners Elastomers Cast Bronze ASTM B 584 Cast Bronze ASTM B 584 Cast Bronze ASTM B 584 Stainless Steel, 300 Series Silicone (FDA approved) Buna Nitrile (FDA approved) Noryl<sup>™</sup>, NSF Listed Stainless steel, 300 series Nickle plated carbon steel


Polymers Springs Ball valve handles





		DIMENSIONS (approximate)															
MOI SIZ		A		В	6	С	;	D	)	E		F		F UNION VAL\		WEI	GHT
in.	mm	in.	mm	in.	mm	in.	mm	in.	mm	in.	mm	in.	mm	in.	mm	lbs.	kg.
3/4	20	11 5/8	295	2 1/8	54	3	76	3 1/2	89	5	127	5 13/16	148	6 7/8	175	14	6.4
1	25	11 5/8	295	2 1/8	54	3	76	3 1/2	89	5	127	6 5/16	160	7 1/4	184	15	6.8
1 1/4	32	13 5/16	338	2 3/4	70	3 1/2	89	5	127	6 3/4	171	N/A	N/A	6 5/16	160	29	13.2
1 1/2	40	13 1/2	343	2 3/4	70	3 1/2	89	5	127	6 3/4	171	N/A	N/A	7 1/2	191	29	13.2
2	50	14 5/16	364	2 3/4	70	3 1/2	89	5	127	6 3/4	171	N/A	N/A	8 5/8	219	36	16.3


DOCUMENT #: BF-975XLSE




#### **TYPICAL INSTALLATION**

Local codes shall govern installation requirements. To be installed in accordance with the manufacturers' instructions and the latest edition of the Uniform Plumbing Code. Unless otherwise specified, the assembly shall be mounted at a minimum of 12" (305mm) and a maximum of 30" (762mm) above adequate drains with sufficient side clearance for testing and maintenance. The installation shall be made so that no part of the unit can be submerged.

Capacity thru Schedule 40 Pipe									
Pipe size	5 ft/sec	7.5 ft/sec	15 ft/sec						
1/8"	1	1	2	3					
1/4"	2	2	3	5					
3/8"	3	4	6	9					
1/2"	5	7	9	14					
3/4"	8	12	17	25					
1"	13	20	27	40					
1 1/4"	23	35	47	70					
1 1/2"	32	48	63	95					
2"	52	78	105	167					





#### **SPECIFICATIONS**

The Reduced Pressure Principle Backflow Preventer shall be rated to 180°F and fully assembled with 90° street elbows and full port ball valves. The main body, access covers and elbows shall be bronze (ASTM B 584), the seat ring and all internal polymers shall be NSF® Listed Noryl<sup>™</sup>. The seat disc elastomers shall be silicone. The first and second check valves shall be accessible for maintenance without removing the relief valve or the entire device from the line. If installed indoors, the installation shall be supplied with an air gap adapter. The Reduced Pressure Principle Backflow Preventer shall be a WILKINS Model 975XLSE.

#### Page 2 of 2